

Greenville Daily WWTP Report

	MGD	Effluent (ppm)					colonies/100mL	
	Effluent flow	pH	BOD	TSS	Total N	Chlorine Residual		Total Fecal Coliform
Tuesday, November 01, 2022	4.6	8.05	5	11		1.02		5
Wednesday, November 02, 2022	4.3	8.25	5	9		0.9		15
Thursday, November 03, 2022	4.4	8.08	4	12		0.92		12
Friday, November 04, 2022	7.1	8.17	4	9		2.2		1
Saturday, November 05, 2022	6.8	7.95	5	17		0.82		6
Sunday, November 06, 2022	6.9	7.82	13	18		2.2		1
Monday, November 07, 2022	7.7	7.4	5	17		1.86		41
Tuesday, November 08, 2022	4.7	7.7	4	7		2.2		2
Wednesday, November 09, 2022	4.4	8.17	3	6		2.2	<	1
Thursday, November 10, 2022	7.6	7.89	3	8		2.2		7
Friday, November 11, 2022	4.5	7.85	4	13		1.18	<	1
Saturday, November 12, 2022	2.4	7.9	4	10		0.9	<	1
Sunday, November 13, 2022	4	7.8	3	7		1.08	<	1
Monday, November 14, 2022	5.1	8.02	4	9		0.75	<	1
Tuesday, November 15, 2022	4.7	7.8	6	10		2.2	<	1
Wednesday, November 16, 2022	3.4	7.87	5	10		2.2		2
Thursday, November 17, 2022	3.3	8.33	4	10		2.2	<	1
Friday, November 18, 2022	3.7	7.98	5	6		2.2	<	1
Saturday, November 19, 2022	3.3	7.98	5	6		1.3	<	1
Sunday, November 20, 2022	5.4	7.93	4	9		2.2	<	1
Monday, November 21, 2022	3.6	7.85	3	10		0.9	<	1
Tuesday, November 22, 2022	3.4	7.88	4	10		2.2		3
Wednesday, November 23, 2022	3.9	7.94	5	10		0.98	<	1
Thursday, November 24, 2022	5.9	8	4	10		2.2	<	1
Friday, November 25, 2022	4.6	7.73	7	18		2.02		1
Saturday, November 26, 2022	5.3	8.02	6	6		1.98	<	1
Sunday, November 27, 2022	4.1	7.85	5	15		1.65	<	1
Monday, November 28, 2022	3.7	7.84	5	33		1.95	<	1
Tuesday, November 29, 2022	8	7.91	3	10		2.2	<	1
Wednesday, November 30, 2022	7.6	7.5	15	26		1.31		7
Total	148.4	xxxx	xxxx	xxxx	xxxx	xxxx		xxxx
Average	4.9	7.92	5	12	#DIV/0!	1.67		2
Max	8	8.33	13	33	0	2.2		41
Min	2.4	7.4	3	6	0	0.75		1