


Greenville Daily WWTP Report									
	MGD		Effluent (ppm)				Colonies/100mL		
	Effluent flow	pH	BOD	TSS	Total N	Chlorine Residual	Greater than/ Less than	Total E. coli	
Tuesday, January 10, 2023	5.9	7.82	5	13		N/A		24	
Wednesday, January 11, 2023	5.7	7.98	5	20		N/A		10	
Thursday, January 12, 2023	4.9	7.84	2	14		N/A		22	
Friday, January 13, 2023	4.4	7.95	5	9		N/A		48	
Saturday, January 14, 2023	4.9	7.98	4	8		N/A		34	
Sunday, January 15, 2023	4.5	7.86		10		N/A		10	
Monday, January 16, 2023	5.2	7.9		8		N/A		5	
Tuesday, January 17, 2023	4.7	7.86		11		N/A		20	
Wednesday, January 18, 2023	11.74	7.85		13		N/A		12	
Thursday, January 19, 2023		7.45		43		2.2			

Total Nitrogen for the month of January:

Influent: 16.5    Effluent: 7.90



River stage is at 29.95 ft