

Greenville Daily WWTP Report									
	MGD		Effluent (ppm)				Colonies/100mL		
	Effluent Flow	pH	BOD	TSS	Total N	Chlorine Residual	Greater than/ Less than	Total E. coli	
Tuesday, March 07, 2023	4.4	7.78	4	6		N/A		24	
Wednesday, March 08, 2023	8.9	7.83	3	7		N/A		7	
Thursday, March 09, 2023	11.1	7.61	14	9		N/A		38	
Friday, March 10, 2023	8	7.68	5	8		N/A		8	
Saturday, March 11, 2023	10.3	7.86	4	8		N/A		20	
Sunday, March 12, 2023	14	7.51		13		2.2		0	
Monday, March 13, 2023	10	7.68		29		2.2		0	
Tuesday, March 14, 2023	8.1	7.79		19		1.78		4	
Wednesday, March 15, 2023	7.2	7.92		8		1.25	<	1	
Thursday, March 16, 2023		7.8		11		1.47			

Total Nitrogen for the month of March: Eff. 6.70



River stage is at 44.67 ft