


Greenville Daily WWTP Report									
	MGD		Effluent (ppm)				Colonies/100mL		
	Effluent Flow	pH	BOD	TSS	Total N	Chlorine Residual	Greater than/ Less than	Total E. coli	
Tuesday, March 21, 2023	6.5	8	9	15		2.06	<	1	
Wednesday, March 22, 2023	6.2	7.8	7	13		0.99	<	1	
Thursday, March 23, 2023	6.4	7.74	10	11		0.76	<	1	
Friday, March 24, 2023	12.7	7.75	6	15		0.75	<	1	
Saturday, March 25, 2023	13.8	7.54	15	16		1.48	<	1	
Sunday, March 26, 2023	8.4	7.77		32		2.2	<	1	
Monday, March 27, 2023	7.9	7.5		37		1.86	<	1	
Tuesday, March 28, 2023	7.5	7.83		13		0.54		5	
Wednesday, March 29, 2023	6.1	7.81		11		0.57		1	
Thursday, March 30, 2023		7.8		8		0.52			

Total Nitrogen for the month of March: Eff. 6.70



River stage is at 40.89 ft