


Greenville Daily WWTP Report									
	MGD		Effluent (ppm)				Colonies/100mL		
	Effluent flow	pH	BOD	TSS	Total N	Chlorine Residual	Greater than/ Less than	Total E. coli	
Tuesday, February 28, 2023	5.3	7.78	4	6		N/A		35	
Wednesday, March 01, 2023	5.3	7.88	4	7		N/A		10	
Thursday, March 02, 2023	8.9	7.9	5	9		N/A		27	
Friday, March 03, 2023	12.1	7.71	6	9		N/A		28	
Saturday, March 04, 2023	8.8	7.8	14	10		N/A		25	
Sunday, March 05, 2023	6.3	7.77	4	8		N/A		22	
Monday, March 06, 2023	6.5	7.88		7		N/A		27	
Tuesday, March 07, 2023	4.4	7.78		6		N/A		24	
Wednesday, March 08, 2023	8.9	7.83		7		N/A		7	
Thursday, March 09, 2023	11.1	7.61		9		N/A		38	

Total Nitrogen for the month of March: Unavailable at the moment



River stage is at 42.46 ft